

# Comhairle Contae Mhaigh Eo

## Appendix 1

### Boil Water Notices

<b>GWS NAME</b>	<b>Location (Municipal District)</b>	<b>Commencement Date</b>	<b>Water Quality Failure</b>	<b>Proposed Action</b>
<b>Sraheens GWS</b>	Foxford (Ballina Municipal District)	12/11/2015	No chlorine in Network	Chlorine levels raised in Plant, negotiations ongoing with DBO operator to take over rising mains and install chlorine boosting.
<b>Knockinakell GWS</b>	Claremorris (Claremorris Municipal District)	11/12/2015	16 Coliforms 1E.coli	Following site Audit HSE sampled and recommended BWN as the GWS has 0 treatment.
<b>Cornboy GWS</b>	Erris (West Mayo Municipal District)	25/08/2016	176 Coliforms	HSE Sampled scheme, twice, both times failed and recommended BWN. Scheme due to scour and disinfect.
<b>Private Well at Ballymachugh,</b>	Ballycastle (Ballina Municipal District)	18/08/2016	5 coliforms	HSE Sampled well, failed and recommended BWN. Owner identified 8 users of well.
<b>Robeen GWS</b>	Claremorris (Claremorris Municipal District)	03/10/2016	1 cryptosporidium oocysts	Further investigation into improvement in source.
<b>Johnstown/ Lavallyroe GWS</b>	Ballyhaunis (Claremorris Municipal District)	08/11/2018	41 Coliforms 19 E.coli	HSE Sampled well, wq failed and BWN was recommended.
<b>Rossport GWS</b>	Erris (West Mayo Municipal District)	08/11/2018	201 Coliforms 83 E.coli	HSE Sampled well, wq failed and BWN was recommended.
<b>Moylough GWS</b>	Sligo County Council	11/01/2019	1 cryptosporidium oocysts	Water Quality Failure, BWN was recommended

Note: On August 13<sup>th</sup> last MCC following consultation with the HSE issued a “Do Not Drink Notice” on Cloonmore/Cloonlavish GWS (near Knock) due to contamination by hydrocarbons(i.e. oil contamination).

<b>GWS NAME</b>	<b>Location (Municipal District)</b>	<b>Commencement Date</b>	<b>Water Quality Failure</b>	<b>Proposed Action</b>
<b>Roy – Bingham GWS</b>	Erris (West Mayo Municipal District)	5/04/2019	1 Coliforms 1 E.coli	Water Quality Failure. Chlorine Dosing Pump to be replaced. BWN was recommended
<b>Errew/Killeen/ Castlehill GWS</b>	Crossmolina (Ballina Municipal District)	9/10/2019	21 Coliforms 8 E.coli	Water Quality Failure, BWN was recommended
<b>Cloonmore/ Cloonlavish</b>	(Claremorris Municipal District)	13/08/2019	Hydrocarbons	Do Not Drink
<b>Barnacarroll</b>	Claremorris Municipal District	20/08/2020	Coliforms & E. coli	Water Quality Failure. BWN was recommended
<b>Irishtown</b>	Claremorris Municipal District	21/05/2021	Coliforms & E.coli	Water Quality Failure. BWN was recommended

Note: On August 13<sup>th</sup> last MCC following consultation with the HSE issued a “Do Not Drink Notice” on Cloonmore/Cloonlavish GWS (near Knock) due to contamination by hydrocarbons(i.e. oil contamination).