

Comhairle Contae Mhaigh Eo

Appendix 1

Boil Water Notices

GWS NAME	Location (Municipal District)	Commencement Date	Water Quality Failure	Proposed Action
Sraheens GWS	Foxford (Ballina Municipal District)	12/11/2015	No chlorine in Network	Chlorine levels raised in Plant, negotiations ongoing with DBO operator to take over rising mains and install chlorine boosting.
Knockinakell GWS	Claremorris (Claremorris Municipal District)	11/12/2015	16 Coliforms 1E.coli	Following site Audit HSE sampled and recommended BWN as the GWS has 0 treatment.
Cornboy GWS	Erris (West Mayo Municipal District)	25/08/2016	176 Coliforms	HSE Sampled scheme, twice, both times failed and recommended BWN. Scheme due to scour and disinfect.
Private Well at Ballymachugh,	Ballycastle (Ballina Municipal District)	18/08/2016	5 coliforms	HSE Sampled well, failed and recommended BWN. Owner identified 8 users of well.
Robeen GWS	Claremorris (Claremorris Municipal District)	03/10/2016	1 cryptosporidium oocysts	Further investigation into improvement in source.
Drumsheen Newtown Group Water Scheme	Bunniconlon (Ballina Municipal District)	09/06/2017	36 Coliforms 5 E. coli	Investigation underway, possible permanent solution is connection into the adjacent Ballina RWSS
Johnstown/Lavall yroe GWS	Ballyhaunis (Claremorris Municipal District)	08/11/2018	41 Coliforms 19 E.coli	HSE Sampled well, wq failed and BWN was recommended.
Rossport GWS	Erris (West Mayo Municipal District)	08/11/2018	201 Coliforms 83 E.coli	HSE Sampled well, wq failed and BWN was recommended.
Moylough GWS	Sligo County Council	11/01/2019	1 cryptosporidium oocysts	Water Quality Failure, BWN was recommended

Note: On August 13th last MCC following consultation with the HSE issued a "Do Not Drink Notice" on Cloonmore/Cloonlavish GWS (near Knock) due to contamination by hydrocarbons(i.e. oil contamination).

GWS NAME	Location (Municipal District)	Commencement Date	Water Quality Failure	Proposed Action
Roy – Bingham GWS	Erris (West Mayo Municipal District)	5/04/2019	1 Coliforms 1 E.coli	Water Quality Failure. Chlorine Dosing Pump to be replaced. BWN was recommended
Errew/Killeen/Castlehill GWS	Crossmolina (Ballina Municipal District)	9/10/2019	21 Coliforms 8 E.coli	Water Quality Failure, BWN was recommended
Cloonmore/Cloonlavish	(Claremorris Municipal District)	13/08/2019	Hydrocarbons	Do Not Drink
Barnacarroll	Claremorris Municipal District	20/08/2020	Coliforms & E. coli	Water Quality Failure. BWN was recommended

Note: On August 13th last MCC following consultation with the HSE issued a “Do Not Drink Notice” on Cloonmore/Cloonlavish GWS (near Knock) due to contamination by hydrocarbons(i.e. oil contamination).